



PRODUCT SPECIFICATION

The STC Box Seal and Intumescent Insert may be specified in either Section 078413 "Penetration Firestopping" or Section 262726 "Wiring Devices".

WALL PLATE GASKETS:

"BOX SEAL" BY STC SOUND CONTROL

1. Manufacturer's standard molded neoprene formed to fit the electrical device and wall plate and in accordance with ASTM C 919.
2. Sound Rating: Increases STC of recessed outlets by 7 dBA or higher according to ASTM E90 (small scale).

ELECTRICAL OUTLET BOX INSERT:

"INTUMESCENT INSERT" BY STC SOUND CONTROL

1. Manufacturer's standard intumescent firestop material to fit interior of metal outlet boxes, tested per UL 263/ASTM E-119 and complying with UL 1479.
2. Fire Rating: UL-listed as a Wall Opening Protective Device for use in 1-hour and 2-hour fire-rated walls.